



605.2020 № 13

Sharq Yulduzi maxallasi (Yangi Tinchlik, Tinchlik, Sho'rabod, Madaniyat go'zarlari) axolisi ichimlik suv ta'minotini yaxshilash maqsadida Mashal maxallasi hududidan qurilishi rejalashtirilayotgan suv inshootiga mavjud tarmoqlarning bosimiga bardoshliligini hisobga olib 3 dona GRANDFAR GF50/250B rusumli nasos agregati o'rnatishni tavsiya qilamiz. Nasos agregati parametrlari H-73 metr, Q-1000 L/minut, 2900 ob/minut, 18.5kwt.

"Samarqand suv ta'minoti"
Nurobod tumani filiali ICHT muxandisi



M.Xakimov